

AHERA REINSPECTION FINDINGS AND RECOMMENDATIONS

School District: BRISTOL TOWNSHIP Building: CLARA BARTON E. S. Date: 12/22/97

Homogenous Sampling Area Material Description: MISCELLANEOUS FLOOR TILES

EHS Project #: 11-97-11178

REINSPECTION FINDINGS FOR ACBM						MANAGEMENT PLANNER RECOMMENDATION	
LOCATION OF ACBM by category	QUANTITY	FRIA- BILITY	CATEGORY (1-7)	JUSTIFICATION	CHANGE IN ASS	PREVENTIVE MEASURES, RESPONSE ACTIONS, INITIAL/ADD CLEAN	SCHEDULE BEGIN FINISH
THROUGHOUT	40,300SF	NO	X	GOOD COND. NON-FRIABLE	NO	PERIODIC INSPECTION	

Were additional samples of this ACBM collected? Yes ☒ No

Date of Review: 12/28/97

Inspector Name: <u>JACK F. CARNEY</u> Inspector Signature: <u><i>[Signature]</i></u> Accreditation #/State: <u>015130/PENNSYLVANIA</u> Expiration Date: <u>3/18/98</u>	Planner Name: <u>JACK F. CARNEY</u> Planner Signature: <u><i>[Signature]</i></u> Accreditation #/State: <u>015130/PA</u> Expiration Date: <u>3/18/98</u>
---	---

I, the LEA's Designated Person, have read and understood the recommendations made above: *James White* Date: 12/28/97

AHERA REINSPECTION FINDINGS AND RECOMMENDATIONS

School District: BRISTOL TOWNSHIP Building: CLARA BARTON E. S. Date: 12/22/97
 Homogenous Sampling Area Material Description: THERMAL PIPE FITTING INSULATION
 EHS Project #: 11-97-11178

REINSPECTION FINDINGS FOR ACBM						MANAGEMENT PLANNER RECOMMENDATION		
LOCATION OF ACBM by category	QUANTITY	FRIA- BILITY	CATEGORY (1-7)	JUSTIFICATION	CHANGE IN ASS	PREVENTIVE MEASURES, RESPONSE ACTIONS, INITIAL/ADD CLEAN	SCHEDULE BEGIN FINISH	
HALLWAY CEILING AREA	80 EACH	YES	6	GOOD COND. FRIABLE ABOVE CEILING	NO	PERIODIC INSPECTION		

Were additional samples of this ACBM collected? Yes No

Date of Review: 12/28/97

Inspector Name: <u>JACK F. CARNEY</u> Inspector Signature: <u>[Signature]</u> Accreditation #/State: <u>015130/PENNSYLVANIA</u> Expiration Date: <u>3/18/98</u>	Planner Name: <u>JACK F. CARNEY</u> Planner Signature: <u>[Signature]</u> Accreditation #/State: <u>015130/PA</u> Expiration Date: <u>3/18/98</u>
--	--

I, the LEA's Designated Person, have read and understood the recommendations made above:

James P. [Signature]

1 1